


20AX 2 Way Single Pole Switch Engraved 'EMG LTG TEST' - Grid Module



TECHNICAL SPECIFICATION

| Standard(s) | BS EN 60669-1 |
|-------------------------------|--|
| Voltage Rating | 20 Amp, 250V [~] (20AX − no derating for inductive or fluorescent loads) |
| Contact Gap | Normal Gap |
| Mounting Box Depth (Min) | 35mm |
| Terminal Capacity | 3 x 2.5mm², 2 x 4.0mm², 1x 6.0mm² |
| Earth Terminal Capacity | 3 x 2.5mm², 2 x 4.0mm², 1x 6.0mm² |
| Size | 54.7mm x 25mm x 30.1mm |
| Product Class 1 | Face plate must be earthed |
| Ambient Operating Temperature | -5° to +40°C |
| Recommended Location | Internal Use Only |
| Maximum Installation Altitude | 2000m |
| IP Rating | IP2XD |
| Switched Poles | Single |
| Mains Frequency | 50hz - 60hz |
| Contact Gap Minimum | 3mm |
| Trademarks | The Soho Lighting Company is a registered trade mark number: UK00003313349, EU017906396, Date: 25 May 2018 |

